



200-10000 l
Volumes

6 bar
95°C
Working pressure tank



VTP-3

- H Hot water
- h1 Cold water
- h2 Recirculation. An alternative way out of hot water or joining another boiler
- h8 Drainage
- h9 For immersion electric heater
- h10,h12,h13 Connecting the control-adjusting and measuring fixtures
- h14,h15 Connecting magnesium anode
- h16-h18 Flanges for heat exchanger

V _{tank} , l	Dimensions, mm				Mounting dimensions, mm											
	H	ØD1	ØD	Ød	h1	h2	h8	h9	h10	h12	h13	h14	h15	h16	h17	h18
400	1730	700	600	450	331	1481	75	921	681	1081	1481	781	-	456	906	1306
	1¼"				1¼"	¾"	1½"	½"	1"	Ø210						
500	1980	700	600	450	331	1731	75	1026	681	1231	1731	781	-	456	1031	1531
	1¼"				1¼"	¾"	1½"	½"	1"	Ø210						
750	2035	850	750	600	357	1757	75	1052	707	1257	1757	807	-	532	1057	1557
	1¼"				1¼"	¾"	1½"	½"	1"	Ø300	Ø210					
1000	2085	950	850	700	390	1790	75	1085	740	1290	1790	840	-	565	1090	1590
	1½"				1½"	¾"	1½"	½"	1"	Ø300						
1500	2170	1100	1000	850	430	1830	75	1125	780	1330	1830	880	1380	605	1130	1630
	1½"				1½"	¾"	1½"	½"	1"	Ø300						
2000	2260	1300	1200	1000	471	1871	75	1166	821	1371	1871	921	1421	671	1171	1671
	2"				2"	1"	1½"	½"	1"	Ø350	Ø300					
3000	2365	1500	1400	1150	526	1926	75	1221	876	1426	1926	976	1476	726	1226	1726
	2"				2"	1"	1½"	½"	1"	Ø350	Ø300					
4000	2425	1700	1600	1300	557	1957	75	1252	907	1457	1957	1007	1507	757	1257	1757
	2"				2"	1"	1½"	½"	1"	Ø350						
5000	2925	1700	1600	1300	557	2457	75	1507	907	1770	2457	1007	1957	757	1507	2257
	2"				2"	1"	1½"	½"	1"	Ø350						
6300	2850	2100	1900	Configuration and size of pipes on request of the client												
8000	3600	2100	1900													
10000	4350	2100	1900													